

OFFICE OF THE JOINT COMMISSIONER OF COMMERCIAL TAXES :

BALASORE RANGE : BALASORE.

TENDER CALL NOTICE

No. _____/CT., Dt. _____

As per the decision taken by the Purchase Committee held on 17.01.2014 Sealed Tenders are invited from the intending Manufacturers/ Suppliers/Authorized dealers having valid registration number under Orissa Value Added Tax Act for supply and installation of Sealed Maintenance free batteries (exclusively EXIDE brand) for use in 5KVA UPS in the different sub-ordinate offices working under administrative control of the Joint Commissioner of Commercial Taxes, Balasore Range, Balasore along with buy-back offer of the old batteries as per the specifications given below.

Sl. No.	Location	Old Battery Specification(to be replaced)	No of Old Battery	New Battery specification(to be supplied)	No of New Battery
1	Balasore Range	12 V,42 AH	20	12 V,42 AH	20
2	Balasore Circle	12 V,120 AH	12	12 V,120 AH	12
3	Bhadrak Circle	12 V,42 AH	20	12 V,42 AH	20
	Mayurbhanj Circle	12 V,42 AH	20	12 V,42 AH	20
5	Badadalima Checkgate	12 V,18 AH	8	12 V,18 AH	8
6	Rairangpur A.U.	12 V,42 AH	8	12 V,42 AH	8
7	Jamsola Checkgate	12 V,18 AH 12 V,65 AH	8 16	12 V,18 AH 12 V,65 AH H	8 16
8	Chakasulia pada IP	12 V,18 AH	8	12 V,18 AH	8
9	Laxmannath Checkgate	12 V,100 AH & 12 V,18 AH	14 8	12 V,100 AH & 12 V,18 AH	14 8
10	Jaleswar I.P.	12 V,18 AH	8	12 V,18 AH	8
		TOTAL	150		150

Specific Terms & Condition

1. The bidder must be the OEM or the Authorized Distributor or Agent or Supplier for the batteries of EXIDE brand and a certificate (original or certified copy) from the manufacturer must be submitted along with the bid document ,in case the bidder is other than the OEM.
2. The batteries proposed to be supplied should be strictly of the specification as mentioned above .No substitute will be entertained and will result in rejection of the bid submitted.
3. All the batteries are to be supplied of same brand and make by the selected bidder. Under no circumstances ,batteries of different brands /makes are to be mixed by one bidder.
4. The batteries must have at least 2 (two) years on site warranty from the date of successful installation .In case batteries found to be defective or develops defect within the warranty period ,the supplier shall be responsible for replacement of those defective batteries at their own cost within three days of receipt of information.
5. In order to ensure the performance of these batteries, the selected bidder will be required to submit a bank Guarantee equal to 10% of the total cost of the order within 5 days of installation. Payment for

